

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250578
Address: 3133 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|---------------|----------|----------------------------|
| Driveway Inspection | Tyler Schreck | Passed | Tuesday, November 25, 2025 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | 11/25/25 Tyler S. Driveway is formed and compacted with 4" of clean rock. Approve to pour. 12/05/25 Tyler S. Driveway and slopes are in compliance with city standards. Pass. |
|---|------|--|

Comments: