

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251415

Address: 626 SE GOLDEN LN, LEES SUMMIT, MO 64063628 SE GOLDEN LN, LEES SUMMIT, MO 64063630 SE GOLDEN LN, LEES SUMMIT, MO 64063624 SE GOLDEN LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mitchell Schwarz	Failed	Friday, December 05, 2025

Corrective Action Required:

1 Misc

Truss layout plans onsite are for type B building
-truss hangers are not to plans
-trusses missing bracing

624

626

628

-fireblock wall to ceiling space at rear bedroom(see trusses below is all top plate/rear wall)

-remove sheet rock from walls in garage for inspection

630

Comments: