

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251162

Address: 638 SE BRADFEE ST, LEES SUMMIT, MO 64063640 SE BRADFEE ST, LEES SUMMIT, MO 64063642
SE BRADFEE ST, LEES SUMMIT, MO 64063636 SE BRADFEE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Partial	Monday, December 08, 2025

Corrective Action Required:

1	Misc	11-24-25 Dustin A, Dw has standing water and has not been compacted. 12-8-25 Dustin A, DW is compacted and there is no standing water . Approved to pour , Reminder ground temps need to be above 32 and rising. Dw under commercial permits need to 8 in .
---	------	--

Comments: