

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235207
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Monday, December 08, 2025

Corrective Action Required:

1	Misc	Above-ceiling at elevator smoke screen-corrections: -Complete wiring to SC controller. Complete electrical -Secure wiring within 12" of boxes -Install exit light to rear stairway -Fc ceiling penetrations -Patch holes at ceiling -3rd fl
---	------	--

Corrective Action Required:

2	CORRIDORS	Corridors on all floors-OK
---	-----------	----------------------------

Comments: