



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION

220 SE GREEN ST.
P.O. BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20111096
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081
Inspected On: Friday, April 20, 2012
Inspected By: John Borns
Expiration Date: 6/28/2012 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Friday, April 20, 2012

Corrective Action Required:

1 MISC PROVIDE SAFE PEDESTRIAN ACCESS AT ENTRANCE (NORMAL AND HANDICAPPED)

Corrective Action Required:

2 MISC CHECK ALL INTERIOR ELECTRICAL RECEPTACLES; MAKE ALL SOLID TO BOX

Corrective Action Required:

3 MISC RE-CHECK ALL ELECTRICAL CIRCUIT DESIGNATIONS AT PANEL SCHEDULES. CORRECT / ADD AS NEEDED.

Corrective Action Required:

4 MISC COMPLETE ROOFTOP GAS PIPING SUPPORTS (CLAMPS NOT IN PLACE)

Corrective Action Required:

5 MISC RTU ELECTRICAL RECEPTACLES NOT HOT FOR TEST

Corrective Action Required:

6	MISC	ENSURE RTU'S ARE LABELED BY NUMBER OR LETTER; REFLECT AT PANEL SCHEDULES
---	------	---

Corrective Action Required:

7	MISC	CLEAN ALL DEBRIS AND UNUSED MATERIAL FROM ROOF
---	------	--

Comments: