

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251167

Address: 627 SE BRADFREE ST, LEES SUMMIT, MO 64063629 SE BRADFREE ST, LEES SUMMIT, MO 64063631
SE BRADFREE ST, LEES SUMMIT, MO 64063625 SE BRADFREE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Partial	Monday, December 08, 2025

Corrective Action Required:

1	Misc	11-24-25 Dustin A, Dw has standing water and has not been compacted. 12-8-25 Dustin A, Dw still has standing water in it. 12-8-25 Dustin A, Dw called in again. Still had water 625 but 627 was good so they can pour that side .
---	------	---

Comments: