

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20241951
Address: 3191 NW PARAGON PKWY, LEES SUMMIT, MO 640813150 NW PARAGON PKWY, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Curb Construction	John Jackson	Partial	Tuesday, December 09, 2025

Informational:

1 Misc

11/14/25 Friday (Epic Construction)
Contractor continued to pour curbs on the opposite side of the street.

11/17/25 Monday (Epic Construction)
Contractor continued to pour the curbs for the green spaces curved curbs.

11/18/25 Tuesday (Epic Construction)
Contractor continued to pour curbs to connect storm boxes, curved curbs, and green space curbs separation. I reminded the contractor to repair honey comb areas mainly around curbs and storm boxes.

12/08/25 Monday (Epic Construction)
Contractor is doing some tie-ins curbs today. Contractor will be doing more curbs & sidewalks.

12/09/25 Tuesday JMJ (Epic Concrete , Third party Braun testing)
Contractor poured curbs on West and East bridge. Reminded the contractor to use white cure. Contractor covered all concrete poured.

Comments: