

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252810

Address: 1224 SE WINDBREAK DR, LEES SUMMIT, MO 64081
1222 SE WINDBREAK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Failed	Wednesday, November 26, 2025

Corrective Action Required:

2	MISC	sheetrock missing behind fireplace and tub shower enclosures.
---	------	---

Comments: