

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20114943, Building Permit - Commercial

Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground John Borns Partial Friday, April 20, 2012

Electrical Inspection

- Commercial

Partial Correction

1 MISC OK TO COVER WHEN READY LIGHTNING PROTECTION RING

CONDUCTOR AND GROUND RODS PER PR-2 TRENCHED OUTSIDE BUILDING WALL FROM D.2/9 TO DD/8 TO DD/0.2 TO B/0.2 TO B/11 TO F/11 TO F/1; THEN FROM DD/0.2 TO B/0.2

Partial Correction

2 MISC OK TO COVER WHEN READY 1" PVC BURIED CONDUIT FROM

EAST END OF BLDG ~ 55L.F. EAST TO QUAZITE BOX

Corrective Action Required

3 MISC OK TO POUR WHEN READY LIGHT POLE BASE FOR

RELOCATION OF L.P. #73 -- CONDUIT THERETO AND GROUND

ROD + CONNECTION SUBJECT TO APPROVAL WHEN

INSTALLED

Comments: