

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252573
Address: 2630 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Tuesday, December 09, 2025

Corrective Action Required:

1	Misc	2630 SW Firefly Ln
		- Irrigation outlet needs labeled as non gfci
		- Egress ladders needed in window wells
		- Obtain issued irrigation permit
		- final driveway inspection needed

Comments: