

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245783
Address: 1001 NE MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	John Jackson	Partial	Tuesday, December 09, 2025

Informational:
1 Misc 12/09/25 Tuesday JMJ (Gen. Titians, Sub. George Shaw Construction, UES testing)
Contractor pass proof roll UES inspector required the contractor to add gravel with a higher moisture.
Contractor plans to pour concrete tomorrow for handicap stall. Southwest side of the building.

Comments: