

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251957
Address: 240 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection	Dustin Agcopra	Failed	Wednesday, December 10, 2025

Informational:
1 Misc 10-30-25 Dustin A, Erosion control is in place and maintained.
12-10-25 Dustin A, Construction entrance needs to be reworked . Talked with Centric and they are going to rework it today and they new gravel coming

Comments: