CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242294

Address: 1609 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mark Harding Failed Wednesday, December

Residential 10, 2025

Corrective Action Required:

1 Misc sump pump discharge to extend 36" from foundation

This item is 9 months old. 9 fees added to permit

complete asap.

10 day notice will be issued and case sent to law dept.

Comments: