



PROJECT: Q39 TI – LEE’S SUMMIT, MO
CHANGE NARRATIVE: ADDENDUM 01
DOCUMENT DATE: 12/09/25

The general contractor shall obtain approval of the Construction Manager before beginning the Work defined in this revision to the originally issued contract documents dated 11/17/25 and any/all subsequent contract modifications.

SUMMARY

- City comments

ARCHITECTURAL

A000 COVER SHEET

PROJECT INFORMATION

- a. Revise latest revision and issue date.

DRAWING INDEX

- a. Revise latest revision and date revised columns.

CODE ANALYSIS

- a. Add deferred submittals for fire alarm and fire protection.
- b. Add “unisex lavatories required / provided 0/1” to schedule.
- c. Add “unisex water closets required / provided 0/1” to schedule.
- d. Revise male lavatories required / provided from “3/2” to “2/2”.
- e. Revise female lavatories required / provided from “3/2” to “2/2”.
- f. Revise male water closets/urinals required / provided from “4/4” to “3/3”.
- g. Revise female water closets required / provided from “4/4” to “3/3”.

A003 LIFE SAFETY PLAN

RESTROOM FIXTURE COUNT

- a. Schedule added in its entirety.

CODE ANALYSIS

- a. Add “unisex lavatories required / provided 0/1” to schedule.
- b. Add “unisex water closets required / provided 0/1” to schedule.
- c. Revise male lavatories required / provided from “3/2” to “2/2”.
- d. Revise female lavatories required / provided from “3/2” to “2/2”.
- e. Revise male water closets/urinals required / provided from “4/4” to “3/3”.
- f. Revise female water closets required / provided from “4/4” to “3/3”.

END OF NARRATIVE