

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20241971
Address: 3828 SW RAVENGATE PL, LEES SUMMIT, MO 64082
Inspected On: Wednesday, December 10, 2025
Inspected By: Development Center
Expiration Date: 1/9/2026 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Monday, October 07, 2024

Corrective Action Required:

1 Miscellaneous
Correction

water meter appears to high for grade
Sump pump extension is not installed
Sod and splash pads are not installed

Comments: