

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235207  
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Failed	Tuesday, December 09, 2025

Corrective Action Required:  
1 Misc Above-ceiling at elevator smoke screen-corrections:  
-Install exit light to rear stairway (at lower and 1st floor)

Corrective Action Required:  
2 CORRIDORS Corridors on all floors-OK

**Comments:**