

**City of Lee's Summit**  
**Department of Planning & Development**  
Phone (816) 969-1600 Fax (816) 969-1619

**Final Inspection Report**

**Inspection Summary**

---

Permit #: PRCOM20111096, Building Permit - Commercial  
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Planning</b>	Chris Hughey	Temporary C of O	Friday, April 20, 2012

Corrective Action Required  
1

Required for Final Certificate of Occupancy. All parking lot asphalt, curbing, sidewalks shall be installed.

Corrective Action Required  
2

Required for Final Certificate of Occupancy. All parking space striping, pedestrian crossings, and ADA parking space signs shall be installed.

Corrective Action Required  
3

Required for Final Certificate of Occupancy. All landscaping material shall be installed.

Corrective Action Required  
4

Required for Final Certificate of Occupancy. All construction debris and materials shall be removed.

Corrective Action Required  
5

Required for Final Certificate of Occupancy. The approved Final Development Plans show the west elevation wall as having a brick facade. However, a primarily stucco facade with brick trim was constructed. This change of material is acceptable since it is in keeping with the design of the addition. However, please submit revised elevation plans (Sheet A200) to show the constructed facade.

**Comments:**