

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251166

Address: 655 SE BRADFREE ST, LEES SUMMIT, MO 64063657 SE BRADFREE ST, LEES SUMMIT, MO 64063659
SE BRADFREE ST, LEES SUMMIT, MO 64063653 SE BRADFREE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Failed	Thursday, December 11, 2025

Informational:

1	Misc	1st layer okay to cover. 2nd layer in attic space complete
---	------	---

Corrective Action Required:

2	Misc	657-missing drywall in dead space 657/655 wall (laundry)
---	------	--

Comments: