

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20240778
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Jamie Simerly	Partial	Friday, December 12, 2025

Informational:

1 Misc

4-14-25 DP. Crew poured sidewalk on the north side of the property that connected to existing. They used AB3 and had adequate amount, compacted. They had expansion join laid out where it needed to go and cross slopes looked to be in compliance. I told them with the SW being so wide, that I will confirm cross slopes on final.

08/12/25 Jamie S, Sidewalks panel cracked on east section of sidewalk connecting to east parking lot.

12/12/25 Jamie S, Sidewalk panel has been replaced and is compliant with city standards.

Comments: