

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20243308  
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Tyler Schreck	Partial	Friday, December 12, 2025

### Corrective Action Required:

1	PW-Sanitary Sewer Testing	Sanitary Sewer Testing needs to be completed. 12/12/25 Tyler S. Manhole Vac Test: MH-A2 Pass, MH-A3 Pass, MH-A4 Pass, MH-A5 Pass. MH-A6 Pass. MH-A7 Pass. MH-A8 Fail, MH-A9 Pass. MH-B1 Fail. MH-B2 Pass. MH-B3 Pass.
---	---------------------------	--

### Comments: