

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251415

Address: 626 SE GOLDEN LN, LEES SUMMIT, MO 64063628 SE GOLDEN LN, LEES SUMMIT, MO 64063630 SE GOLDEN LN, LEES SUMMIT, MO 64063624 SE GOLDEN LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Mitchell Schwarz	Failed	Monday, December 15, 2025

Corrective Action Required:

1	Misc	-no more than one conductor per lug in panel -copper main bonding jumper shall be minimum #4
---	------	---

Comments: