

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20253506
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Monday, December 15, 2025

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">-Fire approval required-Outstanding Fees of \$5201.00 has not been paid-Gas service not approved. Submit revised gas plan that matches current installation-Provide access to RTU per IMC 306-Provide address at doors-Receptacle in restrooms and near mop sink not gfci-protected-Receptacles located within six ft of sink must be gfci-protected-Provide label for exit doors per IBC 1010.1.9.4(2)-Provide seal for fire door |
|---|------|--|

Comments: