

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252500
Address: 2607 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Monday, December 15, 2025

Corrective Action Required:

1	Misc	2607 SW Firefly - laundry outlet needs to be gfci protected - Dishwasher outlet needs to be gfci protected - Sump outlet needs to be labeled as non gfci - Splash blocks needed - Final sidewalk and driveway inspections needed - As graded plot plan needed
---	------	---

Comments: