

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242294
Address: 1609 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Monday, December 15, 2025

Corrective Action Required:

1	Misc	sump pump discharge to extend 36" from foundation
---	------	---

This item is 9 months old. 9 fees added to permit complete asap.
10 day notice will be issued and case sent to law dept.

Comments: