

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245783
Address: 1001 NE MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	John Jackson	Partial	Monday, December 15, 2025

Informational:

1 Misc

12/15/25 Monday JMJ (Gen. Titians, Sub. George Shaw Construction, UES Testing)

Proof passed on the parking lot on the Westside of the facility. The handicap area was poured last week. UES inspector suggest that contractor cover the pavement surface to stop from freezing. Enough area will be covered to allow temperature to rise above freezing 32 degrees.

Comments: