

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252137
Address: 2233 SW CROWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Tuesday, December 16, 2025

Corrective Action Required:

2	Misc	2233 SW Crown
		- house numbers missing
		- Security screws needed in front door hinges
		- Sump must discharge 36" from the foundation
		- 1/2" thru bolts required at deck post to beam connections
		- Obtain irrigation permit

Comments: