

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242079
Address: 1604 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Tuesday, December 16, 2025

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Upload engineer report on pier changes from plans- Uncover manhole- Uncover water meter for inspection- Pending sidewalk inspection- Final grading and sod- Install gutters and downspouts- Provide splash pads- Sump discharge to be 36" away from foundation
---	------	---

Corrective Action Required:

2	Misc	Final sidewalk inspection needed
---	------	----------------------------------

Comments: