

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20253506
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Tuesday, December 16, 2025

Corrective Action Required:

1	Misc	-Provide access to RTU per IMC 306 -Provide seal (intumescent/smoke seals tested per UL 1784) for fire door
---	------	----------------------------------------------------------------------------------------------------------------

**OK to stock items

Comments: