

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20255269
Address: 1905 NE CATALINA AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Wednesday, December 17, 2025

Corrective Action Required:

1	Misc	-Cannot use waste stack to vent sink
		-Provide combustion air openings per code. Min 100 square inches per clear opening. upsize 133% if grills are installed

**OK to rock. The above will be checked at final

Comments: