

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20241951

Address: 3191 NW PARAGON PKWY, LEES SUMMIT, MO 64081
3150 NW PARAGON PKWY, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	John Jackson	Partial	Wednesday, December 17, 2025

Informational:

1 Misc

11/20/25 Thursday JMJ (Epic Construction)

Contractor passed proof roll test on geo-grid and rock on roads, drive lanes, parking areas around the business 470 & NW View High Drive construction entrance SE of roundabout.

12/16/25 Tuesday JMJ (Epic Construction, Braun Interet Testing)

Contractor retested the proof roll on the entrance lane and the Westside and South sub grade graveled parking lots of the business building.

Comments: