



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120225, Building Permit - Commercial
Address: 635 SW 2ND ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Passed	Tuesday, April 24, 2012
Gas Piping Inspection - Commercial	John Borns	Passed	Tuesday, April 24, 2012
Gas Service Inspection - Commercial	John Borns	Passed	Tuesday, April 24, 2012

Comments: RELEASE GAS SERVICE. ACT OK TO COVER AFTER ALL TOP PLATE BORES ARE FIRE-BLOCKED AND TEMPORARY LIGHTING WIRING IS REMOVED FROM ABOVE CEILING AT CATERING ROOM.