

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20243308  
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Mandrel</b>	Tyler Schreck	Partial	Wednesday, December 17, 2025

Corrective Action Required:

1	Misc	12/16/25 Tyler S. Mandrel test was was done on A line and B line. Test between Manhole A2 to A3 pass, A3 to A4 pass, A4 to A5 pass, A5 to A6 pass, A6 to A7 pass, A7 to A8 pass, A8 to A9 pass, A6 to B1 pass, B1 to B2 pass, B2 to B3 pass. Still need to test A0 to A1 and A1 to A2.
---	------	--

**Comments:**