

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253205

Address: 219 NW ORCHARD CT, LEES SUMMIT, MO 64063219 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Wednesday, December 17, 2025

Informational:

1	Misc	Above ceiling attic screw pattern is good, behind furnace ductwork screw pattern is good mud and tape good , ok to set ductwork.
---	------	--

Comments: