



LEE'S SUMMIT MISSOURI

Scope of Work Statement

Applicant: Cynthia Fortner, Agent for AT&T Contractor Homeowner/Tenant? (Circle one)
 Primary Contact: self Phone: 615-314-7225 Email: cynthia.fortner@gdit.com

Project Address: 1097 NW Black Twig Lane, Lees Summit, MO 64081-1905
 Name of Owner: American Tower Company Phone: 615-314-7225
 Residential Commercial? (Circle one) Generator Replacement

Water service repair/replace: Work in right of way?
 Sewer service repair/replace: Work in right of way?
 Electrical service repair/replace Amperage: 200 (Engineer required of ≥ 400)
 HVAC repair/replace
 Uncovered deck: Covered deck: Square feet: _____

 Accessory Structure: Description: N/A Square feet _____

 Interior Alterations: Description: N/A Square feet _____

 Addition: Description: N/A Square feet _____

 Retaining wall over 48" General Dynamics
Information Technology
CHRISTOPHER KIRKHAM
 Swimming pool Electrical contractor _____ Plumber (NG?) N/A
 Lawn irrigation
 Other: Cost of project including labor \$ \$25,000.00
 Detailed description of work: Backup diesel generator replacement (40 sf)

Remove existing concrete pad and diesel generator. Install new 4' x 8' concrete pad and new diesel generator. Install 200A ATS/Camlock on existing AT&T shelter exterior wall. Connect existing electrical service with new equipment.

AFFIDAVIT: I hereby certify that I have the authority to make the foregoing application and that the application, the best of my knowledge, is complete and correct and that the permitted construction will conform to the regulations in the Codes adopted by the City of Lee's Summit and all applicable ordinances.

Cynthia Fortner
 Signature of Applicant

Cynthia Fortner as Agent for AT&T
 Printed Name of Applicant

12/17/25
 Date