

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251167

Address: 627 SE BRADFREE ST, LEES SUMMIT, MO 64063629 SE BRADFREE ST, LEES SUMMIT, MO 64063631
SE BRADFREE ST, LEES SUMMIT, MO 64063625 SE BRADFREE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Failed	Thursday, December 18, 2025

Informational:

1	Misc	1st layer sheet rock- okay
		2nd layer sheet rock screw pattern in attic space only- okay

Corrective Action Required:

2	Misc	Seal top of wall throughout 631 -gaps around truss into wall back bedroom 629/627 -gaps around truss into wall back room 627/625 -seal around feeder cable
---	------	--

Comments: