

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

### Inspection Summary

Permit #: PRCOM20242774  
Address: 1000 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Thursday, December 18, 2025

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none"><li>-Complete corrections for all other departments</li><li>-Provide address</li><li>-Provide final special inspections report</li><li>-Complete exterior</li><li>-Label disconnects</li><li>-Open hand holes in light poles for inspection</li><li>-Complete electrical at exterior</li><li>-Paint exterior metallic gas lines</li><li>-Label panels</li><li>-Provide panel schedules</li><li>-Close open electrical</li><li>-Install floor mats at entries</li><li>-Install baseboard and non absorbent finish at restrooms</li><li>-Grab bar at back wall of women's room to be min 42" from side wall</li><li>-complete flooring</li><li>-install cover plates</li><li>-Provide Backflow at beverage dispensers</li><li>-Secure and label ESO</li></ul> |
|---|------|---|

Comments:

