

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253665
Address: 2618 SW FARM FIELD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|-----------------------------|
| All Rough Inspection - Residential | Drew Fischer | Failed | Thursday, December 18, 2025 |

Informational:

| | | |
|---|------|--|
| 1 | Misc | Portal frame front and rear are good and ok to cover |
|---|------|--|

Corrective Action Required:

| | | |
|---|------|---|
| 2 | Misc | 2618 SW Farmfield Fire block wall to soffit transition in back basement bedroom - soffits in basement require 3/4" sheeting on sides - Add strapping to vertical plumbing vent pipes - Protect all wire within 6' of attic access |
|---|------|---|

Comments: