

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20253665  
Address: 2618 SW FARM FIELD RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Drew Fischer	Failed	Friday, December 19, 2025

Informational:	
1 Misc	Portal frame front and rear are good and ok to cover
Corrective Action Required:	
2 Misc	2618 SW Farmfield - soffits in basement require 3/4" sheeting on sides

**Comments:**