



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20111096, Building Permit - Commercial
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Wednesday, April 25, 2012

Corrective Action Required
1 MISC

MAINTAIN SAFE PEDESTRIAN ACCESS AT ENTRANCE (NORMAL AND HANDICAPPED)

Corrective Action Required
3 MISC

COMPLETE PERMANENT PANEL SCHEDULES

Corrective Action Required
6 MISC

AFFIX PERMANENT NUMERICAL DESIGNATION LABELS ON RTU'S

Comments: