



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20111096, Building Permit - Commercial  
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Partial	Wednesday, April 25, 2012

Corrective Action Required  
1 MISC

MAINTAIN SAFE PEDESTRIAN ACCESS AT ENTRANCE (NORMAL AND HANDICAPPED)

Corrective Action Required  
3 MISC

COMPLETE PERMANENT PANEL SCHEDULES

Corrective Action Required  
6 MISC

AFFIX PERMANENT NUMERICAL DESIGNATION LABELS ON RTU'S

**Comments: PREVIOUSLY-ISSUED TEMPORARY OCCUPANCY CERTIFICATE THROUGH 6/28/2012 CONTINUES IN EFFECT.**