

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252117
Address: 1216 SE RANCLAND ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Monday, December 22, 2025

Informational:
1 Misc 10-15-25 Dustin A, DW is formed and compacted approved to pour.
10-23-25 Dustin A, Dw is poured , forms still on
12-22-25 Dustin A, Dw has been poured to city specs

Comments: