

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251165

Address: 628 SE BRADFREE ST, LEES SUMMIT, MO 64063630 SE BRADFREE ST, LEES SUMMIT, MO 64063632
SE BRADFREE ST, LEES SUMMIT, MO 64063626 SE BRADFREE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Monday, December 22, 2025

Corrective Action Required:

1	Misc	11-24-25 Dustin A, Dw has standing water and has not been compacted. 12-8-25 Dustin A, Dw has been compacted and is free of standing water. Approved to pour (Reminder ground temp must be 32 deg and rising) 12-22-25 Dustin A, Dw is poured to city specs.
---	------	---

Comments: