

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242774
Address: 1000 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, December 22, 2025

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Provide State inspections report -Complete exterior -Complete electrical at exterior -Paint exterior metallic gas lines -Install non absorbent finish at restrooms and backroom sink -Clean debris from rooftop -Provide receptacle within 25' of rooftop equipment
---	------	---

Comments: