



FIRE DEPARTMENT

**Prevention Division
(816)969-1300**

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20250182	Date:	December 24, 2025
Project Title:	CHICK-FIL-A	Applicant:	
Location:			
1001 SW JEFFERSON XING, LEES SUMMIT, MO 64081		AEGIS FIRE PROTECTION LLC	
Type of Work:		11937 W 119TH ST #263	
Occupancy Group:	A-2	OVERLAND PARK, KS 66213	
Description:	CHICK-FIL-A - NEW RESTAURANT	Primary: (913) 825-0343	
WITH DINE IN AND DRIVE THRU			
Construction Type:	Type VB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Ball drip not shown on the riser.

Action Required: Provide ball drip.

2. Fire Department Connection does not show size of Storz connection.

Action Required: Please show a 4" storz with a 30 degree elbow.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.