



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120415, Building Permit - Commercial
Address: 2401 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Partial	Thursday, April 26, 2012

Corrective Action Required
1 MISC

*THIS INSPECTION ONLY COVERS THE 1ST SPRAY BOOTH. THE
2ND SPRAY BOOTH IS NOT INSTALLED YET.

CORRECT THE FOLLOWING FOR THE 1ST SPRAY BOOTH:

- OUTSIDE DIFFUSERS
- SECURE ALL THE MC CABLES ABOVE THE BOOTH
- CONDUIT TO MIXING RM SEALED BOTH SIDE?
- COMPLETE FIRE DEPARTMENT LIST

*OK TO USE THE BOOTH

Comments: