CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251167
Address: 627 SE BRADFREE ST, LEES SUMMIT, MO 64063629 SE BRADFREE ST, LEES SUMMIT, MO 64063631 SE BRADFREE ST, LEES SUMMIT, MO 64063625 SE BRADFREE ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Failed	Monday, December 29, 2025

Informational:

1	Misc	1st layer sheet rock- okay 2nd layer sheet rock screw pattern in attic space only- okay

Corrective Action Required:

2	Misc	Seal top of wall throughout 629/631 Rear of wall 629 not sealed roof line 627/625 -rear of separation wall not sealed at roof line

Comments: