

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250046  
Address: 636 SE WOOD LN, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Partial	Tuesday, December 30, 2025

**Corrective Action Required:**

1	Misc	12-30-25 Dustin A, Dw has been formed and compacted. Good to pour as long as ground temp is above 32 degrees . Please call to have ground temp checked before pouring.
---	------	--

**Comments:**