

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20254263  
Address: 1122 SE RANCLAND ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, December 30, 2025

Corrective Action Required:

1	Misc	-uncover covered front porch (can not verify truss hold downs) -plans call for (2) 2x12 above foyer entry -move electrical outlet in flex room to furr out wall -support and complete bath vents throughout
---	------	--

**Comments:**