

Blackwell Apts.



CITY OF LEE'S SUMMIT  
WATER UTILITIES DEPARTMENT  
220 SE GREEN ST, LEE'S SUMMIT, MO 64064  
PHONE: (816) 969-1930 FAX: (816) 969-1935 EMAIL: backflow@cityofs.net

Print Form

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER Blackwell Apts. B-3

SERVICE ADDRESS

LOCATION OF BACKFLOW ASSEMBLY ON PROPERTY  
Sprinkler Control Room.

DATE OF TEST 12-15-2025 TIME 2:15  A.M.  P.M. SUPPLY PRESSURE 74 LBS AIR GAP (2 X SUPPLY DIAMETER) SUPPLY        IN. GAP        IN.  PASS  FAIL

TYPE OF ASSEMBLY  DC  RP  DCDA (DETECTOR)  RPDA (DETECTOR)  PVB\* (SEE BOTTOM OF FORM) MANUFACTURER AMES MODEL Deringer 30 SIZE 4" SERIAL NUMBER C18272

HEIGHT OFF FLOOR 4 FT    IN PROTECTION FROM: FREEZING  YES  NO FLOODING  YES  NO COMMENTS Horizontal NEW INSTALLATION  YES  NO

INITIAL TEST	PASSED	FAILED	FINAL TEST AFTER REPAIR	PASSED	FAILED
REDUCED PRESSURE PRINCIPLE ASSEMBLY:	<input type="checkbox"/>	<input type="checkbox"/>	REDUCED PRESSURE PRINCIPLE ASSEMBLY:	<input type="checkbox"/>	<input type="checkbox"/>
RELIEF VALVE OPENED AT <u>      </u> PSID (2 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>	RELIEF VALVE OPENED AT <u>      </u> PSID (2 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure	<input type="checkbox"/>	<input type="checkbox"/>	2ND CHECK held backpressure	<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/>	<input type="checkbox"/>	NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow <u>      </u> PSID (5 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>	1ST CHECK held in direction of flow <u>      </u> PSID (5 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
DIFFERENCE (1st check - relief) <u>      </u> PSID (3 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>	DIFFERENCE (1st check - relief) <u>      </u> PSID (3 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>

NOTE: Failure of any of the above items, requires repair.

INITIAL TEST	PASSED	FAILED	FINAL TEST AFTER REPAIR	PASSED	FAILED
DOUBLE CHECK VAVLE ASSEMBLY:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	DOUBLE CHECK VAVLE ASSEMBLY:	<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow <u>1.8</u> PSID (1 PSID or more)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1ST CHECK held in direction of flow <u>      </u> PSID (1 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2ND CHECK held backpressure	<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held in direction of flow <u>1.4</u> PSID (1 PSID or more)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2ND CHECK held in direction of flow <u>      </u> PSID (1 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUTOFF VALVE leak tight	<input checked="" type="checkbox"/>	<input type="checkbox"/>	NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/>	<input type="checkbox"/>

NOTE: Failure of any of the above items, requires repair.

APPLICATION: <input type="checkbox"/> COMMERCIAL <input type="checkbox"/> IRRIGATION <input checked="" type="checkbox"/> FIRE LINE <input type="checkbox"/> FIRE LINE BY-PASS **METER # <u>      </u> **METER READ <u>      </u> <input type="checkbox"/> POINT OF USE	COMMENTS <u>Single check bypass tested. 1.8 psi</u>
---	--

THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE

TESTED BY (PRINT) <u>Barry Blackburn</u> (SIGNATURE) <u>[Signature]</u>	REPAIRED BY (PRINT) <u>      </u> (SIGNATURE) <u>      </u>
COMPANY <u>Alliance Fire Protection</u>	FINAL TEST BY (PRINT) <u>      </u> (SIGNATURE) <u>      </u>
MISSOURI CERTIFICATION NUMBER <u>34-6515</u> EXPIRATION DATE <u>5-31-2028</u>	OWNER OR OWNER'S REPRESENTATIVE <u>      </u> DATE <u>      </u>

\* If an existing PVB is beyond repair and needs replacement, it should be replaced by a DC or RP to meet current State and City regulations. New PVB installations or replacements are not permitted.  
\*\* METER # and METER READ for the fire line by-pass meter on detector assemblies are required.  
Missouri State Regulation 10 CSR 60-11-010(6)(E) requires testers to report results of tests and inspections to the customer and water supplier.