

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245783
Address: 1001 NE MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Wednesday, December 31, 2025

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	Soffits in 04, 05, 155, 135, 101, soffit in front of reception 158 Hard lids at 012-013, 136, 137, &149, 101, 103, 130-133, 123, 031-034, 036-038 ACT-139-145, 150, 151, 152, 154, 155, 03-011, 015, -017 ok for borders
---	--	---

Corrective Action Required:

2	Misc	Locker rm 035-Add support wires at grid splices
---	------	---

Comments: